



Certificate of Pendulum Testing

This is to certify that on the date listed below Pendulum Slip Safety test was undertaken to record slip resistance with slider 96 (hard rubber – shod feet)

Average PTV Rating Wet: 31

GF213

GF General Formulations GmbH

13/03/21



Margus Saareoks
Operations Director

Work undertaken on behalf of Slip Safety Services Ltd.

**SLIPSAFETY
SERVICES**
Delivering expert floorcare

 0203 355 5018
 info@slipsafety.co.uk
 www.slipsafety.co.uk

